

**CERL PAINT LABORATORY TESTING REPORT**

Lab Report No.: 97L134

Date: 15 August 1997

CID: A-A-3130

Manufacturer: Alocit

Batch No:

Product Name: Aquacoat 28.15

<b>Analysis:</b>	<b>Min</b>	<b>Max</b>	<b>Result</b>	<b>Pass</b>
Condition in container			OK	YES
Application properties, spray:			OK	YES
Application properties, roller:			OK	YES
Performance Characteristics:				
Cure, ASTM D 4752	3		4	YES
Degree of Blistering, ASTM D 714	10		10	YES
Degree of Rust rating, ASTM D 610	10		10	YES
Adhesion, ASTM D 3359 Method A	4B		5B	YES
Adhesion, Score Area by Knife		2mm	1	YES
Color	Visual match		OK	YES

Recommendation:

Accept   X   Reject   

Remarks:

Signature: